

**LiquiMix Pty Ltd - Sample B - Civiox LV100 / Elaston W80 / Opalon S30 /
Renderfill C750 / Opalon S30 - Wet Sliptest KO260821-2A**

26 Aug 2021


Slip Resistance Classification of New Pedestrian Surfaces - AS4586:2013 Appendix A

Date Tested:	26 Aug 2021
Test Report Number:	KO260821-2A
Client Name & Address:	LiquiMix Pty Ltd - PO Box 108, BRISBANE MARKET, QLD 4106
Test Site / Surface Tested :	Sample B - Civiox LV100 / Elaston W80 / Opalon S30 / Renderfill C750 / Opalon S30 (Applied to Concrete Paver)
Sample Information :	Samples and Test Information Supplied by Client
Wet Pendulum Test carried out using :	Slider 96 (4S) Rubber slider
Any Variations to Standards	Variation of Standards only 1 Sample Available for testing
Testing Officer / Approved Signatory:	Kathryn Ording
Pendulum in use - Calibration Date :	#0604 - 19.02.2020 - Munro-Stanley Portable Skid Tester

Signature of Approved Signatory :



Test Results :

Sample No.	Swing 1	Swing 2	Swing 3	Swing 4	Swing 5	Mean BPN of last 3 swings :	SCV :	Surface Picture
Area 1A	56	56	56	56	56	56	N/A	
Area 1B	60	60	60	60	60	60	N/A	
Area 1C	60	60	60	60	60	60	N/A	
Area 1D	62	62	61	61	61	61	N/A	
Area 1E	60	60	60	60	60	60	N/A	

Variation to Standard Mean BPN Slip Resistance Value (SRV) 59

CLASSIFICATION using Slider 96 (4S Slider) P5 = > 54

